

# PUBLIC PRIVATE SCHOOL

## STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC PRIVATE SCHOOL INSPECTION REPORT



Geocoded 25.713206/-80.406330

**PURPOSE:**  
 ROUTINE  
 CONSTRUCT.  
 COMPLAINT  
 QA SURVEY  
 OTHER

REINSPECTION  
 CHANGE OF OWNER  
 CONSULTATION  
 EPIDEMIOLOGY  
 PREOPENING

**TYPE:** Public School

CENSUS	FEMALES	MALES
920	460	460

**NAME** Howard D. McMillian Middle  
**ADDRESS** 13100 SW 59 Street **CITY** Miami  
**OWNER** M-DCSB Food and Nutrition **ZIP** 33183  
**PERSON IN CHARGE** Hilca J. Thomas **PHONE** (305) 385-6877

**E-MAIL** hthomas@dadeschools.net;jodiaz@dadeschools.net;ipalacio@dadeschools.net;TEQuigley@dadeschools.net

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
10:00	12:00	02/17/2015	82515	13-51-06592

**RESULTS:**

Satisfactory  
 Incomplete  
 Unsatisfactory  
 OUT OF BUSINESS

**Correct Violations by**  
 Next Inspection  
 8:00 AM on

RE-INSPECTION DATE

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

SCHOOL SANITATION	BUILDINGS	SANITARY FACILITIES	WATER SUPPLY	LIQUID/SOLID WASTE	VECTOR/VERMIN CONTROL	SAFETY	FOOD	OTHER
1. School Site	4. Construction	8. Natural Ventilation	11. Cleanliness & Repair	15. Handwash Facilities	21. Sewage Disposal	26. First Aid Kit	27. Food Insp. Rpt.	28.
2. Playground Equipment	5. Maintenance & Repair	9. Mechanical Ventilation	12. Toilet Facilities	16. Showers/Fixtures	22. Solid Waste	29.		
3. Athletic Equipment	6. Lighting/Foot-Candles	10. Provided/Accessible	13. Separation of Sexes	17. Shower Water Temp.	23. Infestation/Control			
	7. Heating, Ventilation, A/C	11. Cleanliness & Repair	14. Fixture Ratio	18. Installed/Operated/Maintained	24. Brush/Trash			
		12. Toilet Facilities	15. Handwash Facilities	19. Drinking Fountains	25. Water Collection/Drainage			
		13. Separation of Sexes	16. Showers/Fixtures	20. Approved Source				

**COMMENTS AND INSTRUCTIONS**

**Violation #5** Clean/replace ceiling tiles located in first floor near to the stairwell #1 and the girls locker room.  
 Fix leak in walls located in stairwell #1 and stair #2 area.  
 Scrub floor in two showers located in girls locker room.  
 Scrape peeling paint on wall under board in clasrom 205 and stair #1 area.  
**Code Reference** FAC: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

**Violation #6** Replace light bulbs located in stairwell area #2 and next to the girls locker room.  
**Code Reference** FAC: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

**Violation #19** Repair one drinking water fountain located next to the bathroom 285.  
**Code Reference** FAC: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

**INSPECTION CONDUCTED BY:** Maria Adrover **PHONE:** (305) 623-3500 ex.  
**INSPECTION COND SIGNATURE:** *Maria Adrover* **PHONE 2:** (305) 623-3500 ex.  
**COPY OF REPORT RECEIVED BY:** *Hilca J. Thomas* **DATE:** 2/17/2015

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY PUBLIC HEALTH UNIT  
Public/Private School



Name: Howard D. McMillian Middle

Date: 02/17/2015

Identification No: 13-51-06592

Comments and Instructions (Continued from Page 1):

Copy of Report  
Received By:

Inspector Maria Adrover

Page 2